



Our ref: 32120-1-25429

1 September 2026

Accenture
Level 34, 2 The Esplanade
PERTH 6000

Attention: Ross Maher
Email: ross.maher@accenture.com

COOLJARLOO ENERGY HUB – WIND FARM AND BESS

Following our provision of the preliminary noise impact assessment for the above project (HSA Ref : 36957-1-25429) it is understood that there is consideration in hosting 18 modules in the BESS, in place of the 16 that were modelled in the aforementioned preliminary noise impact assessment.

Given the insignificant contribution to the calculated noise levels in the surrounding area by the BESS with 16 modules, in the event that 18 are utilised, the difference to the overall noise impact would be negligible.

It is anticipated that any approval of the project would include conditions that require the confirmation of the final selections of the proposed equipment for the project prior to building permit – hence – it is suggested that any update to the noise impact assessment, and the associated negligible increase in noise levels associated with the BESS, be incorporated at that stage of the project.

We trust the above provides sufficient clarification on the preliminary noise impact assessment, and any concerns there may be in the considered change to the number of BESS modules.

Yours faithfully,
for **HERRING STORER ACOUSTICS**